

**MEDFIELD DEPARTMENT OF PUBLIC WORKS  
MEDFIELD, MASSACHUSETTS**

**WELLS 3 & 4 WATER TREATMENT PLANT  
CONTRACT DPW-2021-05**

**ADDENDUM NO. 3**

**April 13, 2021**

**NOTICE TO ALL BIDDERS:**

Sealed Bids from Subcontractors for the filed sub-bid categories designated herein will be received until **2:00 PM prevailing time on Wednesday, April 14, 2021** for the following filed sub-bids:

- Masonry
- Miscellaneous and Ornamental Iron
- Waterproofing, Damp Proofing and Caulking
- Roofing and Flashing
- Painting
- Plumbing
- Heating, Ventilation and Air Conditioning
- Fire Protection

Sealed Bids from Subcontractors for only the Electrical Work filed sub-bid category will be received until **2:00 PM prevailing time on Friday, April 16, 2021.**

All filed sub-bids shall be submitted online at [www.Projectdog.com](http://www.Projectdog.com) and entitled “**[Filed Sub-bid Classification]** Filed Sub-bid for Wells 3 & 4 Water Treatment Plant, Town of Medfield, Massachusetts” All electronic bids are compiled in real time upon bid close and published forthwith on ProjectDog. Official sub-bid tabulations shall be posted on ProjectDog.

General Bids will be received until **2:00 p.m.** prevailing time on **Wednesday, April 28, 2021.** All bids shall be submitted online at [www.Projectdog.com](http://www.Projectdog.com) and entitled “**Wells 3 & 4 Water Treatment Plant, Town of Medfield, Massachusetts**” All electronic bids are compiled in real time upon bid close and published forthwith on ProjectDog. Official bid tabulations shall be posted on ProjectDog.

The attention of all eligible bidders submitting bids for the above referenced project is called to the following Addendum to the drawings and specifications (Contract Documents). The items set forth herein, whether of omission, addition, substitution, or clarification, are all to be included in and form a part of the proposed work.

Any and all addenda shall be posted online at Projectdog.com. Each individual or firm recorded as having received the contract documents will be notified by email if and when addenda are issued. Hard copies of addenda will not be mailed or faxed to plan holders. It is the sole responsibility of the Bidder to review any and all addenda prior to the bid opening either online or at the offices of Projectdog, Inc.

If a bid is submitted prior to an Addendum being issued, the Bidder will receive an e-mail notification for informational purposes only. The Bidder must review the addendum, retract the bid, acknowledge all addenda, and re-submit the bid. If a Bidder fails to acknowledge all addenda their bid may be rejected by the Awarding Authority.

*This Addendum addresses the following:*

- *Specifications and Drawings*
- *Questions from Contractors and Answers*

### **SPECIFICATIONS AND DRAWINGS:**

Make the following changes, revision, additions, and/or deletions to the Contract Documents:

#### **Division 0 – Section 00020– INVITATION TO BID**

- On page 1 of Section 00020 – Invitation to Bid – Instructions to Bidders, delete Paragraph 2 in its entirety and replace with the following:

“2. Sealed Bids from Subcontractors for the filed sub-bid categories designated herein will be received until **2:00 PM prevailing time on Wednesday, April 14, 2021** for the following filed sub-bids:

- Masonry
- Miscellaneous and Ornamental Iron
- Waterproofing, Damp Proofing and Caulking
- Roofing and Flashing
- Painting
- Plumbing
- Heating, Ventilation and Air Conditioning
- Fire Protection

Sealed Bids from Subcontractors for only the Electrical Work filed sub-bid category will be received until **2:00 PM prevailing time on Friday, April 16, 2021.**

All filed sub-bids shall be submitted online at [www.Projectdog.com](http://www.Projectdog.com) and entitled “**[Filed Sub-bid Classification]** Filed Sub-bid for Wells 3 & 4 Water Treatment Plant, Town of Medfield, Massachusetts” All electronic bids are compiled in real time upon bid close and published forthwith on ProjectDog. Official sub-bid tabulations shall be posted on ProjectDog.”

## **Division 16 – Section 16001– ELECTRICAL (Filed Sub-Bid Required)**

- On page 1 of Section 06001 – ELECTRICAL (Filed Sub-Bid Required), delete paragraph 1.1D – Reference Drawings in its entirety and replace with the following:

“D. Reference Drawings: Work of this Filed Sub-Bid is shown in part or in full on the following Contract Drawings: G-1, C-1, C-5, A-4, A-5, A-6, A-9, A-19, A-20, M-2, E-1, E-2, E-3, E-4, E-5, E-6, E-7, E-8, E-9, E-10, E-11, E-12, E-13, E-14, E-15, E-16, E-17, E-18, E-19, E-20, I-1, I-3, I-4, I-8, I-10, I-11, I-12, I-13, I-14, I-16, I-17, and I-18.”

### **QUESTIONS AND ANSWERS**

Question 1: Please confirm the drawings related to filed electrical sub-bids and specifications outside of Division 16 are included for coordination purposes only and shall not be part of the electrical sub-contractors bid.

Answer 1: Refer to Addendum 3.

Question 2: What the DWSRF Number is for this project?

Answer 2: The Drinking Water State Revolving Fund (DWSRF) number for this project is 6799.

Question 3: Please confirm the pump operating points on M-2 are correct for the backwash waste pumps 1 & 2. Please confirm if the attached pump will be acceptable.

Answer 3: The design operating condition for the backwash waste pumps 1 & 2 is operating point two, 200gpm at 114 TDH. Operating point three, 400gpm at 369 TDH is for if both pumps running in parallel. Pump acceptability shall be determined during shop drawing review after contract award.

Question 4: Can you please clarify the contract sum line item for the “FORM FOR SUB-BID”. It appears both the contract sum line and the all-inclusive lines are where the bid value should go.

Answer 4: On the FORM FOR SUB-BID (Page 00301-12), The first line in the second paragraph is the bid for the sub-bidder work at the Water Treatment Plant only, excluding any sub-bidder work at Well Station 3 or Well Station 4. The second and third lines are the bids for Well Station 3 and Well Station 4, respectively, if applicable to the sub-bidder. (If not applicable, these lines can be ignored). The final line (line 4) is a summation of the previous three (3) lines for a total bid price.

### **END OF ADDENDUM NO. 3**